



**AT STRUCTURE  
OR APPURTENANCE**

**AT  
LAWN AREA**

**NOTES:**

1. MAXIMUM CROSS-SLOPE OF SIDEWALK IS 1:50.
2. SIDEWALK ACCESS RAMP IS TO BE 7 INCH THICK CLASS K CONCRETE. LANDING PAD TO BE 8 INCH THICK PERVIOUS CONCRETE.
3. PROVIDE 1/2 INCH WIDE EXPANSION JOINT BETWEEN NEW CONCRETE CONSTRUCTION AND BACK EDGE CURB, CONCRETE GUTTER, OTHER PAVED AREAS, BUILDINGS, WALLS, POLE BASES AND OTHER STRUCTURES/ APPURTENANCES.
4. EXPANSION JOINT: 1/2 INCH WIDE PREMOULDED EXPANSION JOINT MATERIAL, SEAL WITH CAULKING SEALANT 1/2 INCH WIDE 5/8 INCH DEEP.

**CITY OF ROCHESTER**

**PERVIOUS CONCRETE  
SIDEWALK  
AND DRIVEWAY**

**ISSUED** 12-1-15

**REVISED**

**NON-STANDARD  
DWG.NO.S608-39**